
Landis Plastics Maintenance Report Summary from 1991 to 1996

After MB-50 Oil Purifier Installation in 1992





	Pe	riodic	Oil Anal	lysis I	Repo	rt			Č	OILF Registered Title	URE	SYST OllPure Ted	EMS hanologies, In	S.
Addres Ci Telephos	ss: 1207. ity: Mont ne: 219-	North Sicello 583-5583	xth Street	State: 1N Zip: 47960 Fax: 219-583-4098 le: Maintenance Manager				Note: 24 oil samples were submitted after one MB-50						
Date	Sample No.	Oil or Equip. I.D.	Sample Status	Solid C	tontamin 10µ	ation Par	ticle Co	unt in	1 cc 75µ	ISO Code	Water in ppm	TAN mg of KOHlom	Viscosity in SUS	OilPure Color Code
1/25/96 1/25/96	1 2 3 4 5 6 7 8 9 100 111 12 15 16 17 18 19 21 22 3 24 26	1 2 3 4 4 5 6 7 7 8 9 10 111 12 15 16 17 18 19 21 22 23 24 26	Since May 92	64 37 71 189 171 189 101 22 226 101 22 134 67 108 172 70 107 127 104 149 188 60	31 12 29 61 36 57 31 14 41 24 32 35 80 40 40 76 30 30 30 30 85 180 56 180 57 76 30 30 30 40 40 40 40 40 40 40 40 40 40 40 40 40	15 4 9 19 12 21 21 3 3 11 19 17 7 34 20 19 12 17 17 10 30 34 56 21	3 0 0 0 0 4 0 0 4 0 0 4 0 6 6 9 6 16 11 4 4 4 4 4 4 4 4 7 9 9 9 9 9 9 9 9 9 9 9	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0		13/11 12/9 13/10 15/11 15/11 15/11 15/12 12/11 14/11 14/11 15/12 14/12 14/12 14/11 15/13 13/11 14/11 16/14 14/12 1/17 1/17 1/17 1/17 1/17 1/17 1/17 1	33 41 47 40 49 36 29 21 27 30 34 36 32 26 28 27 96 28 32 27 27 27	0.51 0.31 0.30 0.42 0.29 0.51 0.39 0.51 0.40 0.37 0.37 0.77 0.22 0.26 0.36 0.36 0.40 0.39 0.44		
			TEST COMPARISON FROM THIS YEAR OIL TEST REPORT ON FEBUARY 8, 1996											
										1 1 1 1 1 1				

Summary Report of Maintenance Saving during 1991 to 1995

- Servo valve Reduction from 160 to 7 pieces.
- Oil leakage Reduction from **6,100 to 4,300 gal (29.5%)**.
- Cylinder Rebuild Reduction from 16 to 7 pieces.
- Extruder Rebuild Reduction from 8 to 4 pieces
- Subcontracted Maintenance (Sagamore Expenditure)
 Reduction from \$46,537 to \$14,689 (68.4%).

LANDIS PLASTICS MAINTENANCE SUMMARY 1995 MONTICELLO PLANT

The following is a brief review of last year's activities in the Maintenance Department. Basically, most of the numbers show a slight improvement over last year's numbers and a significant improvement over numbers from five (5) years ago.

One of the more significant items for this year's report is the start and implementation of our own Plant PM program. Last year at this time, we did away with the Sagamore Heating & Cooling maintenance agreement. We have been doing our own in-house PM and maintenance on chillers, air conditioners, towers, heaters, etc. The expenditure figures show that we have reduced our cost to Sagamore by approximately two thirds (2/3). We have trimmed our PM schedule to a Spring & Fall schedule and feel that this has been sufficient to meet our needs. Emergency calls and major rebuilds were at a minimum last year.

The annual infrared scan has proven to be a useful tool. Our number of occurrences has dropped almost fifty (50) percent since our first scan. Not only has it pointed out problem areas in immediate need of repair, but it has served as an educational tool in pointing out specific areas to be on the lookout for in everyday inspections. Note that the 1993 reading was taken by a different company, and it was not consistent with readings taken before or after 1993 and are not considered as accurate.

It appears that the bolt gauge which was purchased in 1992 paid for itself in approximately one (1) year. Our tiebar loss dropped from six (6) down to less than two (2) per year. We have been able to quickly set and maintain a much closer tolerance on the stretch of the tiebars. This also reduces downtime and the amount of shim and mold work necessary to run good parts.

Keeping our oil clean still remains a priority. Many positive results are a direct result of keeping the oil cleaner and cooler. New oil has an average ISO of 16/13. Our target was 14/10, and we have achieved as low as a 12/10 on about half of our presses. This is the finding of our last oil sampling, and we are due for another sampling in January of 1996.

Last summer was one of the hottest on record, and it sure put our cooling systems to the test. We were able to run all summer with minimal downtime associated to high oil temperature on presses.

The number of times that we pulled a screw is down approximately one third (1/3). The number of pullings has dropped from eleven (11) down to three (3) on the bucket machines. The number of pullings on the old RTE machines dropped from twenty two (22) down to eleven (11). We are now running RTE in new presses and have only had to pull screws one (1) time in each machine. Other machines average about two (2) pullings per year.

One disappointing figure has not changed much this year. Pump loss remains at an average of twenty four (24) for the year. We have made some changes in equipment, etc., but have seen no real positive effect at this time. This is obviously an area that needs more work and research.

The following chart reflects some numbers and trends over the last five (5) years:

Frank J Ruger

Landis Plastics Plant locates in Monticello, Indiana has installed a rotational MB-50 oil purifier to provide oil dialysis cleaning operation on 26 units of plastic injection molders. Frank Rupe, maintenance manager, kept good track record of his maintenance cost for **Benchmarking during 1991 to 1995**.

MB-50 oil purifier shows significant improvement in productivity and **80% overall maintenance reduction** while **production capacity is double** during this time. All of these savings happens when all hydraulic oil is kept continuously clean as shown in the Periodic Oil Analysis report. Average oil cleanliness is **ISO Code 14/11**, water content is under 19 ppm and Total Acid Number (TAN) is 0.40 mg KOH /gm that is close to the same value in new oil.